




FILTER SETS 225 COMPACT (LEH)

DESCRIPTION

Vasco recommends cleaning the filters in your ventilation unit 3-monthly and 6-monthly replacement. Cleaning can be done with a vacuum cleaner. Replacement is easily indicated by the dirt filter message on the supplied control element: after operation the LED lights up orange 2x:



Replace the filters (supply and return air) with official filter sets for Vasco ventilation units of the heat recovery type. Available from wholesalers or the Vasco "Accessory Shop". Reset the dirt filter message by pressing for at least 4 seconds simultaneously the "position 1" and "timer" buttons until the LED lights up green.



TECHNICAL FEATURES

On ventilation units of type 225 Compact, the filters are accessible from the front of the unit. The filter tray must be opened to gain access to the supply and return filters respectively. To do this, slide the 2 black door latches inwards. A standard filter set in the ventilation unit is an F7/M5 filter set.

*Depending on the quality of the outside air, there is sometimes a need to replace the F7 filter more often, hence a filter replacement set with 2x F7 filters.

Type ventilation unit	Dimensions [lxwxh mm]	Filter classification EN779 - ISO16890	Material	Image filter set
225 Compact (LEH)	260x125x30	F7 - ISO ePM1 55%	Fibreglass paper	
	260x120x35	M5 - ISO ePM10 50%	Filter frame made of cardboard	
225 Compact (LEH)	260x125x30	F7 - ISO ePM1 55%	Fibreglass paper	
		F7 - ISO ePM1 55%	Filter frame made of cardboard	