

# Filter sets 225 Compact (LEH)

## Description



Vasco recommends cleaning the filters of your ventilation unit with a Hoover every three months and replacing them every six months. The need for replacement is easily indicated by the dirt filter indicator on the control element provided: when replacement is required, the LED indicator will light up orange twice.

### Dirt fi lter indication + reset

After operation, the LED lights up orange 2x :



Replace the filters (supply and return air) with official filter sets for Vasco ventilation units type D. Available from wholesalers or the Vasco 'Accessory Shop'. Then reset the dirt filter message by pressing the 'position 1' and 'timer' buttons simultaneously for at least 4 seconds, until the LED lights up green.



## Technical specifications

In type 225 Compact (LEH) ventilation units, the filters are accessible at the front of the unit. To access the supply and return filters, open the filter door by sliding the two black door latches inwards. The standard filter set in this ventilation unit consists of an F7 filter for supply and an M5 filter for exhaust. Depending on the quality of the outside air, the F7 filter may need to be replaced more frequently. Therefore, we also offer a filter replacement set with 2x F7 filters.

Type ventilation unit	225 Compact (LEH)	225 Compact (LEH)
Dimensions lters (l x w x h mm)	260 x 125 x 30 (F7) 260 x 120 x 35 (M5)	260 x 125 x 30
Filter ratings EN779 - ISO 16890	F7 – ISO ePM1 55% M5 – ISO ePM10 50%	F7 – ISO ePM1 55% F7 – ISO ePM1 55%
Material	· Fibreglass paper · Filter border made of cardboard	· Fibreglass paper · Filter border made of cardboard
Filter sets		